



Water Quality | ANNUAL REPORT **2020**



Informe Anual 2020
Calidad de Agua Potable

Este informe contiene información muy importante sobre su agua potable.
Para información en español, por favor llame al 954-973-6786.



The City of Coconut Creek is committed to delivering the best quality drinking water possible. We remain vigilant in meeting the challenges of new regulations, source water protection, water conservation, and community outreach and education while continuing to serve the needs of our water customers. Thank you for allowing us to continue providing you and your family with quality drinking water. Well-informed customers are our best allies.

COCONUT CREEK CITY COMMISSION




Becky Tooley
MAYOR



Joshua Rydell
VICE MAYOR



Lou Sarbone
COMMISSIONER



Sandra L. Welch
COMMISSIONER



Jackie M. Railey
COMMISSIONER

A MESSAGE TO OUR RESIDENTS

“We encourage residents to attend our monthly Commission meetings held on the 2nd and 4th Thursday of each month at 7PM in the City Commission Chambers located at 4800 West Copans Road.”

Definitions

AL - Action Level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

MCLG - Maximum Contaminant Level Goal is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL - Maximum Contaminant Level is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MRDL - Maximum Residual Disinfectant Level is the highest level of a disinfectant allowed in drinking water. There is convincing evidence that additions of a disinfectant is necessary for control of microbial contaminants.

MRDLG - Maximum Residual Disinfectant Level Goal is the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

pCi/L - picocuries per liter, used to measure radioactivity

ug/L - Micrograms per liter or parts per billion (PPB)

PPB - Parts Per Billion, one part by weight of analyte to one billion parts by weight of the water sample.

PPM - Parts Per Million, one part by weight of analyte to one million parts by weight of the water sample.

N/A - Not Applicable

ND - Not Detected

TT - Treatment Technique is the required process intended to reduce the level of a contaminant in drinking water.

Level 1 Assessment - Is defined as an evaluation to identify the possible presence of sanitary defects, defects in distribution system coliform monitoring practices, and the likely reason that the system triggered the assessment.

Results

The table shows the results of our monitoring for the period of January 1 to December 31, 2020 and includes test results in earlier years for contaminants sampled less than once a year. Test results are for the most recent testing done in accordance with the regulations. The table contains the name of each substance, the highest level allowed by regulations (MCL), the ideal goals for public health (MCLG), the amount detected, the usual sources of such contamination, a key, and reference units of measurement.



Lead In Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Coconut Creek is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.

Immuno-compromised Persons

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider.

EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 800-426-4791

Test Results

Microbiological Contaminants

CONTAMINANT	SAMPLING DATE	TT VIOLATION	RESULT-MONTH PERCENTAGE (%)	MCLG	MCL	LIKELY SOURCE OF CONTAMINATION
Total Coliform Bacteria	Jan - Dec 2020	No	Negative	N/A	TT	Naturally present in the environment

Inorganic Contaminants

CONTAMINANT	UNIT OF MEASURE	SAMPLING DATE	MCL VIOLATION	LEVEL DETECTED	RANGE OF RESULTS	MCLG	MCL	LIKELY SOURCE OF CONTAMINATION
Arsenic	(PPB)	May 2020	No	0.32	N/A	0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium	(PPM)	May 2020	No	0.007	N/A	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Fluoride	(PPM)	May 2020	No	0.732	N/A	4	4	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 PPM
Nitrate (as Nitrogen)	(PPM)	May 2020	No	0.329	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	(PPB)	May 2020	No	0.44	N/A	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Sodium	(PPM)	May 2020	No	40.2	N/A	NA	160	Salt water intrusion, leaching from soil.

Disinfectants and Disinfection By-products

CONTAMINANT	UNIT OF MEASURE	SAMPLING DATE	MCL OR MRDL VIOLATION	LEVEL DETECTED	RANGE OF RESULTS	MCLG OR MRDLG	MCL OR MRDL	LIKELY SOURCE OF CONTAMINATION
Total Trihalomethanes (TTHM)	(PPB)	Quarterly 2020	No	32.50	25 - 42	N/A	80	By-product of drinking water disinfection
Chloramines	(PPM)	Monthly 2020	No	2.26	1.52 - 3.56	MRDLG - 4	MRDL - 4.0	Water additive used to control microbes
Haloacetic Acids (HAA5)	(PPB)	Quarterly 2020	No	22.00	14 - 22	N/A	60	By-product of drinking water disinfection


Lead and Copper (Tap Water)

CONTAMINANTS AT THE TAP	UNIT OF MEASURE	SAMPLING DATE	AL EXCEEDED	90TH PERCENTILE RESULT	SAMPLING SITES EXCEEDING AL	MCLG	AL	LIKELY SOURCE OF CONTAMINATION
Lead	(PPB)	June 2020	No	7.10	0	0	15	Corrosion of household plumbing systems; erosion of natural deposits.
Copper	(PPM)	June 2020	No	0.0837	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

Radioactive Contaminants

CONTAMINANT	UNIT OF MEASURE	SAMPLING DATE	MCL VIOLATION	LEVEL DETECTED	RANGE OF RESULTS	MCLG	MCL	LIKELY SOURCE OF CONTAMINATION
Combined Uranium	(ug/L)	05/14	No	0.028	N/A	0	30	Erosion of natural deposits
Radium - 226	(pCi/L)	05/14	No	0.30	N/A	0	5	Erosion of natural deposits

How does your water system work?



Coconut Creek gets its water from Broward County wells that draw from the Biscayne Aquifer which is an underground water supply. Groundwater is withdrawn from the Biscayne Aquifer via wells and then pumped to Broward County's District 2A Water Treatment Plant. The raw water is treated to reduce hardness, filtered, and then disinfected with chloramines to destroy harmful bacteria. Fluoride is then added to the finished water to promote dental health.

Your Water Is Safe to Drink

The City of Coconut Creek is pleased to provide you with the 2020 Annual Water Quality Report. This report is a snapshot of the City's water quality in 2020. As in years past, your tap water met all requirements of the Safe Drinking Water Act as established by the U.S. Environmental Protection Agency (EPA). Included are details about where your water comes from, what it contains, and how it compares to EPA standards.

The City of Coconut Creek purchases treated water from Broward County's District 2A Water Treatment Plant located in Pompano Beach. This plant, like all other water plants in the County, must adhere to a number of strict regulations. The water is tested frequently by Broward County and the City of Coconut Creek. Every month, City utility workers regularly collect water samples from 60 locations within the service area, which includes parts of the City of Parkland. Independent labs test the samples to ensure the integrity of the water.

Source Water Assessment

In 2020, the Florida Department of Environmental Protection (FDEP) performed a Source Water Assessment (SWA) for Broward County. The assessment was conducted to provide information about any potential sources of contamination. The results are available on the FDEP Source Water Assessment and Protection website at <https://fldep.dep.state.fl.us/swapp> or they can be obtained from Broward County by calling 954-831-3250.



About Your Water

POSSIBLE CONTAMINANTS

In order to ensure tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of certain contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animal or human activity.

A woman with dark hair is shown in profile, drinking from a large blue plastic water bottle. She is wearing a black fitness tracker on her left wrist and white earbuds. The background is a plain, light-colored wall.

More information about contaminants and potential effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791.

[epa.gov/sdwa](https://www.epa.gov/sdwa)

Contaminants that may be present in source water include

Microbial

Microbial contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Pesticides & Herbicides

Pesticides and herbicides which may come from a variety of sources, such as agricultural, urban stormwater runoff, and residential use.

Inorganic

Inorganic contaminants such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Organic Chemical

Organic chemical contaminants including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive

Radioactive contaminants which can be naturally occurring or be a result of oil and gas production and mining activities.

Utilities & Engineering

To view the 2020 Annual Water Quality Report, visit:
www.CoconutCreek.net/2020WaterReport

City of Coconut Creek

Utilities & Engineering	954-973-6786
Utility Billing	954-973-6732
Theodore Risberg ENVIRONMENTAL ENG SPECIALIST	954-956-1504
trisberg@coconutcreek.net	

Broward County

Water & Wastewater Services	954-831-3250
Department of Health	954-467-4705

Florida Department of Environmental Protection

Water Resource Management Division	850-245-8624
------------------------------------	--------------

U.S. EPA

Safe Drinking Water Hotline	800-426-4791
-----------------------------	--------------



GET A

***\$100 Rebate**

**High Efficiency
Toilet Replacement**

CoconutCreek.net/WaterConservation

 **CONSERVATION Pays .COM**
1-800-270-9794

A Collaboration of Local Governments

*PREAPPROVAL REQUIRED